


- ① CROSS GUTTER FOR USE WITH TYPES "A-6" AND "A-8" CURB.
- ② APRON THICKNESS TO BE 8" MINIMUM.
- ③ CROSS GUTTER THICKNESS TO BE 8" MINIMUM.
- ④ CLASS "C" CONCRETE.
- ⑤ PLACE 6" BASE UNDER ENTIRE SPANDREL AREA.
- ⑥ WEAKENED PLANE JOINTS TO BE CONSTRUCTED AT 1/3 POINTS ON 25' RADIUS SPANDRELS, AND AT 1/4 POINTS ON 35' RADIUS SPANDRELS.
- ⑦ CONSTRUCT WEAKENED PLANE JOINT(S) PER STANDARD # 208 AT MIDPOINT OF CROSS GUTTERS LESS THAN 40' LONG, OR AT 1/3 POINTS OF CROSS GUTTERS OF 40' OR LONGER.
- ⑧ THIS PORTION OF SPANDREL AND CROSS GUTTER SHALL HAVE AN ADDITIONAL 6 INCHES OF CLASS "B" CONCRETE.
- ⑨ CONSTRUCT EXPANSION JOINT PER STANDARD # 208.
- ⑩ CONSTRUCT WEAKENED PLANE JOINT PER STANDARD # 208.
- ⑪ CONSTRUCT CROSS GUTTER PER STANDARD # 231.

R.C.T.D. STD. No. 209

REVISIONS:

| | | |
|---|---|--------------|
| APPROVED 08/21/01 |  <i>City of La Quinta</i> | STANDARD |
| CHRIS A. VOGT CITY ENGINEER RCE 44250 | | 230 |
| CROSS GUTTER LAYOUT | | SHEET 1 OF 1 |